

Job 1 Service Relay Assessor Checklist				
LFSEPEPA Service entry points				
SLDIEPA Service laying dead insertion				
SLTCLPEPA Testing and Commissioning LP				
Apprentice Name:	Apprentice No:			
Date:	Assessor Name:			
General		Pass	Fail	
Works safely and ensures compliance with health, safety, environment and other regulations and guidelines				
Carries out site specific risk assessment, and reviews in accordance with company procedures				
Confirms all tools, equipment and materials to complete the task are available on site				
The procedure is communicated to and confirmed as understood by any others working on site				
Selects and wears the designated PPE and ensure all site-specific safety equipment is deployed				
Service Laying - Service entry points		Pass	Fail	
Positions the service with minimum damage to the property with no affect to fire resistance or to damp proof courses				
Checks the condition and position of any mete procedures	r box to ensure compliance with			
Assesses the location of the meter installation to ensure it complies with procedural requirements				
Connects the service pipe to the house entry tee or meter box in accordance with procedures				
Connects the emergency control valve in acco	rdance with procedures			
Service laying - Dead Insertion		Pass	Fail	
Visually inspects the existing steel service for s	severe signs of corrosion			



Attaches temporary continuity bonds where required		
Safely clears the service of gas and debris in line with procedures		
Determines the length of pipe required to complete the task		
Confirms the diameter of the service is compatible with the PE pipe diameters and length of service to be used		
Demonstrates the use of "protective devices" to protect the PE pipe during insertion		
Demonstrates the use of a bullet type nose fitting to assist insertion and prevent debris entering the insertion pipe		
Ensures operatives are present at both ends of the job		
Demonstrates the insertion with sufficient pipe available at both ends of the job to allow connection and inspection		
Examines the inserted pipe for defects and takes remedial action as required		
Prepares the inserted service for connection to the main and the house entry point		
Service Laying - Low pressure testing, purging and commissioning	Pass	Fail
Determines the testing requirements for low pressure services		
Determines the testing requirements for low pressure services Assembles the test equipment used for low pressure service testing in accordance with procedures		
Assembles the test equipment used for low pressure service testing in		
Assembles the test equipment used for low pressure service testing in accordance with procedures Confirm the emergency control valve is in the open position and blanked /		
Assembles the test equipment used for low pressure service testing in accordance with procedures Confirm the emergency control valve is in the open position and blanked / plugged off		
Assembles the test equipment used for low pressure service testing in accordance with procedures Confirm the emergency control valve is in the open position and blanked / plugged off Introduce air in to the service until the test pressure of 100 mbar is achieved		



Apprentice Signature	Date
Assessor Signature	Date
Overall Result Pass / Fail	
Feedback (including any evidence towards a distinction grade)	
Feedback	
All records are completed accurately	
Confirms the cap on the tapping tee is securely tightened and leak detect fluid applied	ion
valve in the closed position	
Completes the purge, removes all equipment, caps the emergency control	
On metallic connections – withdraws the internal plug in to the top of the service tee	
On PE connections- drill the main with the integral cutter and withdraw it i the top of the tapping tee;	nio
63 mm diameter service.	nto
not greater than 32 mm diameter, and four seconds for each metre length	
Calculates the purge time as one second for each metre length of service	
Ensures a suitable communication system is in place between the person the main and at the emergency control valve	at
position outside the building	
trap fitted at the emergency control valve - this must vent to an appropriat	
Prepares for commissioning through the provision of a purge hose and fla	ame